

Notified Body pursuant to the Construction Products Regulation
Permission № CPR-26-NB2765/03.05.2018 of
Ministry of Regional Development and Public Works

Certificate of Constancy of Performance № 2765-CPR-0034

In compliance with Regulation (EU) № 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Panic exit devices

*Intended use: for doors on escape routes
(the characteristics and the performances are described in Annex I which is an inseparable part of this certificate)*

placed on the market under the name of

**DEMKA DEMİR KARDEŞLER MAK. İNŞ. TAAH. SAN. VE TİC. LTD.
ŞTİ.**

İvedik OSB. Arı Sanayi Sitesi 1363 Cad. No: 60 Yenimahalle / Ankara – Turkey

and produced in the manufacturing plant

İvedik OSB. Arı Sanayi Sitesi 1363 Cad. No: 60 Yenimahalle / Ankara – Turkey

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 1125:2008

*under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the
constancy of performance of the construction product*

This certificate was first issued on 30.07.2018 and will remain valid until 06.01.2022 or neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

06.01.2021

Manager of SZUTEST Ltd

Asen Hristov



The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Index>

The certificate will be reissued each year after annual surveillance audit

Notified Body pursuant to the Construction Products Regulation
 Permission № CPR-26-NB2765/03.05.2018 of
 Ministry of Regional Development and Public Works

Certificate of Constancy of Performance № 2765-CPR-0034

Annex I

Product: Panic exit devices operated by a horizontal bar

Trade name: DEMKA D15 and DEMKA D1715

Intended use: for doors on escape routes

Performance Characteristics:

Essential Characteristics	Performance					Harmonized Standard
	DEMKA D 15 Type: 365B1322AA	DEMKA D 15 Type: 375A1322AA	DEMKA D 15 Type: 37501322AA	DEMKA D 1715 Type: 375A1322AA	DEMKA D 1715 Type: 37501322AA	
Ability to release	≤ 80 N and ≤ 220 N	≤ 80 N and ≤ 220 N	≤ 80 N and ≤ 220 N	≤ 80 N and ≤ 220 N	≤ 80 N and ≤ 220 N	EN 1125:2008
Durability of ability to release against aging and degradation	Grade: 6, 100 000 cycles	Grade: 7, 200 000 cycles	Grade: 7, 200 000 cycles	Grade: 7, 200 000 cycles	Grade: 7, 200 000 cycles	
Self closing ability C	≤ 50 N	≤ 50 N	≤ 50 N	≤ 50 N	≤ 50 N	
Durability of self closing ability C against aging and degradation	Grade: B 100 000 (≤ 50 N)	Grade: A – 200 000 (≤ 50 N)	Grade: 0 – 200000 (≤ 50 N)	Grade: A – 200 000 (≤ 50 N)	Grade: 0 – 200000 (≤ 50 N)	
Resistance to fire E (integrity) and I (insulation)	Grade B	Grade A	Grade 0	Grade A	Grade 0	
Control of Dangerous substances	NPD	NPD	NPD	NPD	NPD	

Placed on the market under the name of: DEMKA DEMİR KARDEŞLER MAK. İNŞ. TAAH. SAN. VE TİC. LTD. ŞTİ.

Produced in the manufacturing plant İvedik OSB. Arı Sanayi Sitesi 1363 Cad. No: 60 Yenimahalle / Ankara – Turkey

06.01.2021

Manager of SZUTEST Ltd

Asen Hristov



The validity of certificate can be traced on <http://public.szutest.com.tr/Certificate/Index>

The certificate will be reissued each year after annual surveillance audit Page 1 of 1